

Certificate

type approval

for manufacturing of transportable pressure equipment

Certificate-No.: 01 202 644/B-190079-01-T

Applicant: Ningbo Zhengxin
Fire Fighting Equipment Co., Ltd.
Gao Qiao Village, Huangjiabu Town, Yuyao City
Zhejiang Province. P.R. China 315466

Manufacturer: see Applicant

Applicable provisions
and standards: Dir. 2010/35/EU, in compliance with ADR/RID 2021
and EN ISO 17879:2017

Description of
the type: Self-closing cylinder valve for CO₂ (UN 1013),
Material CuZn40Pb2, DN 3 mm,
Test Pressure 450 bar, working pressure 200 bar
working temperature -40°C / +65°C

It is confirmed that the described type is in
compliance with the requirements of the directive
2010/35/EU.


Report-No.: This approval is based on the results of the
type examination report:
CHN/B-190021-2-T dated 03/07/2019 and
CHN/B-210007-2-T dated 07/04/2021

Drawing No.: ZX-2S-06-00 Rev.2

Chemical compatibility: Acc. to ISO 11114-1:2017 the chemical
compatibility for UN 1013 is given.

Validity: This approval is valid for a period
not exceeding ten years. End of period: 07/2029

Halle, 14/04/2021


on behalf
Dipl.-Ing. Stefan Brandt

TÜV Rheinland Industrie Service GmbH
Am Grauen Stein, D-51105 Köln

Notified body according to dir. 2010/35/EU and ADR/RID,
accredited according to EN ISO/IEC 17020 by DAkkS and ZLS.

